

**VILLAGE OF ROMEOVILLE  
REQUEST FOR VILLAGE BOARD ACTION**

Date Prepared: April 13, 2022

Resolution (X)      Ordinance ( )    Informational ( )                      Motion ( )                      Other ( )

Description/Title:                      AN ORDINANCE GRANTING A VARIANCE FROM THE PROVISIONS OF CHAPTER 150 (BUILDING—ELECTRICAL--Conductors—501 W. Taylor Road, Romeoville, Illinois)

Staff Recommendation:                Consider the proposed legislation

PZC Recommendation:                N/A

Required Action:                      Consider the proposed legislation

Summary:                                      The proposed ordinance would grant a variance from the provisions of the 2014 National Electrical Code, as locally amended in the Village. The variance would allow for the use of Stabloy or equivalent aluminum conductors, subject to the condition that such conductors must be larger than size 3/0 and could only be used for the connection of backup electrical generators to the building electrical system and for no other purpose, i.e., the balance of the building electrical system would use copper conductors. The variance is requested to permit greater ease of installation of the backup generators, and would otherwise comply with the 2014 National Electrical Code, in the absence of the local Romeoville amendment.

Option                                      Consider the proposed legislation

---

Prepared by: \_\_\_\_\_      Dept. Director: \_\_\_\_\_      Village Manager: \_\_\_\_\_