



2221 Muriel Court  
Joliet, Illinois 60433

Phone: 815-726-9192

Fax: 815-726-9245

Email: [Tvisvardis@tecorp.us](mailto:Tvisvardis@tecorp.us)

## Proposal

4/25/2023

Mark Lammers  
Village of Romeoville  
Asst. Superintendent of Utilities

Re: Airport Road Lift Station Painting

The Airport Road Lift Station was drained, cleaned out and turned over to Tecorp, Inc. for coating the bottom 12' and floor on the interior. Upon entering the tank Tecorp personnel informed the engineer and owner that the areas above the 12' are showing significant coating delamination. The delamination was not isolated to one section or specific area and was throughout the remainder of the lift station. In order to perform a quality coating, the entire lift station requires abrasive blasting and coating per the same specification of the bottom 12'. If the remainder of the lift station is not coated the areas of delamination will allow corrosion to form and cause damage to the steel subsurface. Additionally, since there is no consistent area that is tightly adhered, the new coating cannot be tied into the existing coating which would leave a gap of exposed steel.

The cost to Abrasive blast and coat the remainder of the interior of the Airport Road Lift Station above 12' per the same specifications as the lower 12' is as follows:

\$26,600.00

Respectfully Submitted

Telly Visvardis  
Project Manager

*A Complete Professional Coating and Lining Service*